

IEC 61850 Certificate - IEC 61850 Certificate #2354

WY9F [Wuhan Guodian-Wuyi Electric Power Automation Equipment Co., Ltd.]

07/08/2021 04:35 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2009PUCA0001
61850 Edition:	Edition 1	Certificate Hash:	911A3978683867E865126875D701F397 A724D1C3965A2054ACBA60FFCD89A 599
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Wuhan Guodian-Wuyi Electric Power Automation Equipment Co., Ltd.	Vendor Artifact Hash:	
Address:	1F Build D, Central China Software Park, No. 1 Guanshan 1st Road, East Lake Hi-tech Zone, Wuhan, China	Umbrella Organization:	
Product:	WY9F	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0.0.1	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/12/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:35 PM - Herbert Falk

- File 2009PUCA0001_KETOP_WY9F.pdf added

Files

2009PUCA0001_KETOP_WY9F.pdf

374 KB

07/08/2021

Herbert Falk