

IEC 61850 Certificate - IEC 61850 Certificate #2359

DF1725IED [Dongfang Electronics Co., Ltd.]

07/08/2021 04:36 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2009PUCA0006
61850 Edition:	Edition 1	Certificate Hash:	F36B1ECCE59F88050B1C2BCB9015D 5B05EE07B51E4C780FAEBBC0D3522 B067EA
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Dongfang Electronics Co., Ltd.	Vendor Artifact Hash:	
Address:	No. 2, Jichang Road, Yantai, China	Umbrella Organization:	
Product:	DF1725IED	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	3.00	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/12/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:36 PM - Herbert Falk

- File 2009PUCA0006_KETOP_DF1725IED.pdf added

Files

2009PUCA0006_KETOP_DF1725IED.pdf

375 KB

07/08/2021

Herbert Falk