

IEC 61850 Certificate - IEC 61850 Certificate #2360

DF1925IED [Dongfang Electronics Co., Ltd.]

07/08/2021 04:36 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2009PUCA0007
61850 Edition:	Edition 1	Certificate Hash:	9F54632447609691E582EB6DE4AB2F6 51F22622B97B7BE7090EC8B5631D16 E0A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Dongfang Electronics Co., Ltd.	Vendor Artifact Hash:	
Address:	No. 2 Jichang Road, Yantai, China	Umbrella Organization:	
Product:	DF1925IED	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/12/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:36 PM - Herbert Falk

- File 2009PUCA0007_KETOP_DF1925IED.pdf added

Files

2009PUCA0007_KETOP_DF1925IED.pdf

376 KB

07/08/2021

Herbert Falk