

# IEC 61850 Certificate - IEC 61850 Certificate #2361

## STS851L [Shanghai Tengen Future Electric Automation Co., Ltd.]

07/08/2021 04:36 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	2009PUCA0008
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	969191D469DFBE803542018B46AE262 7095B88DAA28EE2BC0B784224923CC 161
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Shanghai Tengen Future Electric Automation Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	No. 388, East Kangqiao Road, Pudong, Shanghai, China	<b>Umbrella Organization:</b>	
<b>Product:</b>	STS851L	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	1.2	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/12/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Xuchang KETOP Testing Research Institute Co.(A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:36 PM - Herbert Falk

- File 2009PUCA0008\_KETOP\_STS851L.pdf added

### Files

2009PUCA0008_KETOP_STS851L.pdf	376 KB	07/08/2021	Herbert Falk
--------------------------------	--------	------------	--------------