

IEC 61850 Certificate - IEC 61850 Certificate #2364

Siprotec 7SJ68 [Siemens Power Automation Ltd.]

07/08/2021 04:36 PM - Herbert Falk

Status:	Approved	Certificate Name:	2010PUCA0002
Priority:	Normal	Certificate Hash:	AABA9E4C5B7521B5C27D999FBB6913 BAE909F983BE6E2E1FE3861F8A1E07 6E8A
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Siemens Power Automation Ltd.	Umbrella Organization:	
Address:	4F, No. 37 Yihuai Street, Jiangning Economic & Technological Development Zone Nanjing, P.R. China	Optional Reservation Test:	No
Product:	Siprotec 7SJ68	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	4.7	Publisher Preferred Rates:	
Key Words:	Relay	Publisher Preferred Variants:	
Test Procedure Version:	2.2	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	09/13/2015	Product Variants:	
Standards Tested:	61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:36 PM - Herbert Falk

- File 2010PUCA0002_KETOP_SIPROTEC 7SJ68.pdf added

Files

2010PUCA0002_KETOP_SIPROTEC 7SJ68.pdf

376 KB

07/08/2021

Herbert Falk