

IEC 61850 Certificate - IEC 61850 Certificate #2365

SLP-K130-PS [Sanion Co., Ltd.]

07/08/2021 04:36 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2013TS02751
61850 Edition:	Edition 1	Certificate Hash:	C81D5D0DEFB7604BB4B9E494BCFDC FE6A75CCE4A14326BEE6BF08EC022 56D2C9
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Sanion Co., Ltd.	Vendor Artifact Hash:	
Address:	#208, Acetechno Tower, 12 Dangsang-Ro 2-Gil, Yeongdeungpo-Gu, Seoul Republic of Korea	Umbrella Organization:	
Product:	SLP-K130-PS	Optional Reservation Test:	No
HW Version:	1.0	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/13/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:36 PM - Herbert Falk

- File 2013TS02751_Sanion_SLP-K130-PS_KERI.pdf added

Files

2013TS02751_Sanion_SLP-K130-PS_KERI.pdf	1.13 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------