

IEC 61850 Certificate - IEC 61850 Certificate #2368

wPD [Woodam Tech Co., Ltd.]

07/08/2021 04:36 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2013TS02055
61850 Edition:	Edition 1	Certificate Hash:	16A4DA8CF269FD7297A655D80F1D29 5F13408483461DD0204AD3CB096B93 8EEF
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Woodam Tech Co., Ltd.	Vendor Artifact Hash:	
Address:	Na-304 Ezen Mecha-zone, 117, Hwanggeum-ro Yangchon-eup, Gimpo-si, Gyeonggi-do Republic of Korea	Umbrella Organization:	
Product:	wPD	Optional Reservation Test:	No
HW Version:	HP EliteBook 8570p w/Win 7 Pro	Serial Number:	
SW Version:	1.20.00	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/13/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:36 PM - Herbert Falk

- File 2013TS2055_certificate_WOODAM_wPD-IEC61850Server.pdf added

Files

2013TS2055_certificate_WOODAM_wPD-IEC61850Server.pdf	4.03 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------