

IEC 61850 Certificate - IEC 61850 Certificate #2371

850 [GE Multilin]

07/08/2021 04:36 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74108094-OPE/INC 15-2142
61850 Edition:	Edition 2	Certificate Hash:	5A74118ECA73EB46D76AF8D4BAC38 832E99F6EA49134262B36A5DEC2925 88CCE
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Multilin	Vendor Artifact Hash:	
Address:	650 Markland St. Markham, ON L6C 0M1 Canada	Umbrella Organization:	
Product:	850	Optional Reservation Test:	No
HW Version:	S/N MJ1A15000260	Serial Number:	
SW Version:	1.50	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/17/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:36 PM - Herbert Falk

- File 15-2142_DNV_GL_Certificate-GE-Multilin-850_61850_Server_ed2. added

Files

15-2142_DNV_GL_Certificate-GE-Multilin-850_61850_Server_ed2.pd2.63 MB

07/08/2021

Herbert Falk