

IEC 61850 Certificate - IEC 61850 Certificate #2372

Alstom MiCOM C264 [M/s. Alstom T&D India Ltd.]

07/08/2021 04:36 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	UARC/SASL/C006/2014
61850 Edition:	Edition 1	Certificate Hash:	BA89A373585FB3C752A59F06A9ED4A 728EC27515B981C2E545F0B90F104F4 134
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	M/s. Alstom T&D India Ltd.	Vendor Artifact Hash:	
Address:	19/1, GST Road, Pallavaram, Chennai - 600043, India	Umbrella Organization:	
Product:	Alstom MiCOM C264	Optional Reservation Test:	No
HW Version:	Serial No.: 33013576	Serial Number:	
SW Version:	5.1.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/17/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:36 PM - Herbert Falk

- File Alstom-C264_UARCSASLC0062014.pdf added

Files

Alstom-C264_UARCSASLC0062014.pdf	847 KB	07/08/2021	Herbert Falk
----------------------------------	--------	------------	--------------