

IEC 61850 Certificate - IEC 61850 Certificate #2376

CG Aegis Series Transformer [CG Power & Industrial Solutions Ltd.]

07/08/2021 04:36 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	UARC/PL/C0018/2012
61850 Edition:	Edition 1	Certificate Hash:	EF1E0468FEB762E2FD7F90521EF6B5 8B662346563200554A0B5DFAB2B58C 37BD
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	CG Power & Industrial Solutions Ltd.	Vendor Artifact Hash:	
Address:	A-3 MIDC, Ambad, Nashik, Maharashtra - 422010 India	Umbrella Organization:	
Product:	CG Aegis Series Transformer	Optional Reservation Test:	No
HW Version:	HW001	Serial Number:	
SW Version:	1.10	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.2b	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/17/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:36 PM - Herbert Falk

- File CGL-UARCPLC00182012.pdf added

Files

CGL-UARCPLC00182012.pdf

808 KB

07/08/2021

Herbert Falk