IEC 61850 Certificate - IEC 61850 Certificate #2379

IDV [ZIV GRID Automation S.L.]

07/08/2021 04:36 PM - Herbert Falk

Status: Approved **Priority:** Normal

61850 Edition: Edition 1

61850 Tested Aspects:

Server

Certificate Name: 12131046-MOC/INC E-13-I-197-PR

Certificate Hash: 710C5252E70C3B190EA78CE762CA73 56566288928B864E612488A807AC803

Company: ZIV GRID Automation S.L.

Name:

Umbrella Organization:

Test:

Variants:

Rates:

Variants:

Serial Number:

Publisher Legacy

Publisher Preferred

Publisher Preferred

Vendor Artifact File

Vendor Artifact Hash:

Optional Reservation No

Address: Parque Tecnologico, 210

48170 Zamudio, Bizkaia

Spain

Product: IDV

HW Version:

SW Version: 7.3R

Differential, Protection, Relay **Key Words:**

Test Procedure

Version:

2.3

IEC 61850 Blocks

Certified:

Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group

(B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered

Reporting (B5)

kathy.ellis

Certificate/Result

Reviewer:

Approval Date: 09/17/2015

Standards Tested:

Current Test Lab

Name: **Test Document:**

DNV Netherlands (A)

61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1

Variants:

Subscriber Preferred

Subscriber Legacy

Variants:

Subscriber Preferred

Rates:

Product Variants:

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:36 PM - Herbert Falk

- File E-13-I-197-PR_ZIV_IDV_Certificate.pdf added

Files

E-13-I-197-PR_ZIV_IDV_Certificate.pdf 2.61 MB 07/08/2021 Herbert Falk

1/1 04/30/2024