

IEC 61850 Certificate - IEC 61850 Certificate #2380

B-PRO [M/s. Easun Reyrolle Ltd. (ERLPhase)]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	UARC/SASL/C001/2013
61850 Edition:	Edition 1	Certificate Hash:	C704C97809CB1301D42582432DF01B A2BEE25E11A87B501A85A3830876027 E28
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	M/s. Easun Reyrolle Ltd. (ERLPhase)	Vendor Artifact Hash:	
Address:	98, SIPCOT Industrial Complex, Hosur - 635126, India	Umbrella Organization:	
Product:	B-PRO	Optional Reservation Test:	No
HW Version:	1.0	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/17/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File Easun_Reyrolle_Limited_-_UARCSASLC0012013.pdf added

Files

Easun_Reyrolle_Limited_-_UARCSASLC0012013.pdf	1.7 MB	07/08/2021	Herbert Falk
---	--------	------------	--------------