

# IEC 61850 Certificate - IEC 61850 Certificate #2382

## PCS-931 [Nari-Relays]

07/08/2021 04:37 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	NR3201001-Testing 09-0001
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	7CEB209B31A78E50DE92BC74930CD 46A3767E763DAC2DBA52B6CA3F583 AF7791
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Nari-Relays	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	69 Suyuan Avenue Jiangning, Nanjing 211102, China	<b>Umbrella Organization:</b>	
<b>Product:</b>	PCS-931	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	R1.00	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Differential, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/17/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	NARI-RELAYS Electric Co. Ltd (B)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File NR3201001-Testing\_09-0001\_PCS-931\_Certificate.pdf added

### Files

NR3201001-Testing_09-0001_PCS-931_Certificate.pdf	55.1 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------