

IEC 61850 Certificate - IEC 61850 Certificate #2383

PCS-978 [Nari-Relays]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	Certificate Name:	NR3201001-Testing 09-002
Priority:	Normal	Certificate Hash:	94B7AF2D2C9383AD6707281A13219E 5E5B382EB4E9FC90770484784CBEA6 494A
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Nari-Relays	Umbrella Organization:	
Address:	69 Suyuan Avenue Jiangning, Nanjing 211102, China	Optional Reservation Test:	No
Product:	PCS-978	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	R1.00	Publisher Preferred Rates:	
Key Words:	Protection	Publisher Preferred Variants:	
Test Procedure Version:	2.2	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	09/17/2015	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	NARI-RELAYS Electric Co. Ltd (B)		
Test Document:			
Description This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File NR3201001-Testing_09-0002_PCS-978_Certificate.pdf added

Files

NR3201001-Testing_09-0002_PCS-978_Certificate.pdf	55.1 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------