

IEC 61850 Certificate - IEC 61850 Certificate #2385

PCS-915 [Nari-Relays]

07/08/2021 04:37 PM - Herbert Falk

| | | | |
|--|--|---------------------------------------|--|
| Status: | Approved | Certificate Name: | NR3201001-Testing 09-0004 |
| Priority: | Normal | Certificate Hash: | 12C7C5A82EF411AA414B49E6AAABC 29BBA30124DD7DA3BB5D1CDF9B780 67D195 |
| 61850 Edition: | Edition 1 | Vendor Artifact File Name: | |
| 61850 Tested Aspects: | Server | Vendor Artifact Hash: | |
| Company: | Nari-Relays | Umbrella Organization: | |
| Address: | 69 Suyuan Avenue Jiangning, Nanjing 211102, China | Optional Reservation Test: | No |
| Product: | PCS-915 | Serial Number: | |
| HW Version: | | Publisher Legacy Variants: | |
| SW Version: | R1.00 | Publisher Preferred Rates: | |
| Key Words: | Protection | Publisher Preferred Variants: | |
| Test Procedure Version: | 2.2 | Subscriber Legacy Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Preferred Variants: | |
| Certificate/Result Reviewer: | kathy.ellis | Subscriber Preferred Rates: | |
| Approval Date: | 09/17/2015 | Product Variants: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | NARI-RELAYS Electric Co. Ltd (B) | | |
| Test Document: | | | |
| Description | | | |
| This certificate and its information was migrated from a previous database | | | |

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File NR3201001-Testing_09-0004_PCS-915_Certificate.pdf added

Files

| | | | |
|---|---------|------------|--------------|
| NR3201001-Testing_09-0004_PCS-915_Certificate.pdf | 55.1 KB | 07/08/2021 | Herbert Falk |
|---|---------|------------|--------------|