

IEC 61850 Certificate - IEC 61850 Certificate #2386

PCS-9611 [Nari-Relays]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: NR3201001-Testing 09-0005
61850 Tested Aspects:	Server	Certificate Hash: D05A1B8F7401DD417D2633325361366 8A0AE188EE233C236DEC8348324939 8A8
Company:	Nari-Relays	Vendor Artifact File Name:
Address:	69 Suyuan Avenue Jinagning, Nanjing 211102, China	Vendor Artifact Hash:
Product:	PCS-9611	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	R1.00	Serial Number:
Key Words:	Relay	Publisher Legacy Variants:
Test Procedure Version:	2.2	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	09/17/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	NARI-RELAYS Electric Co. Ltd (B)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File NR3201001-Testing_09-0005_PCS-9611_Certificate.pdf added

Files

NR3201001-Testing_09-0005_PCS-9611_Certificate.pdf	55.2 KB	07/08/2021	Herbert Falk
----------------------------------------------------	---------	------------	--------------