

IEC 61850 Certificate - IEC 61850 Certificate #2388

Sepam M87 [Schneider Electric]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	Schneider_VAL_M87-ACE850_V2.0
61850 Edition:	Edition 1	Certificate Hash:	A2C51AA872C06EA86EEFBFD2EB631 360CF3179853F678E861399F3F99E3F 12E8
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric	Vendor Artifact Hash:	
Address:	Cities Business - Energy Division Usine M4, 38050 Grenoble Cedex France	Umbrella Organization:	Schneider Electric
Product:	Sepam M87	Optional Reservation Test:	No
HW Version:	ACE850 2.0	Serial Number:	
SW Version:	8.01	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/17/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Schneider-Electric China (B)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File Schneider_VAL_M87-ACE850_V2.0_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

Schneider_VAL_M87-ACE850_V2.0_Certificate.pdf	356 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------