

IEC 61850 Certificate - IEC 61850 Certificate #2389

MiCOM P143 [Schneider Electric]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	Certificate Name:	Schneider_VAL_MiCOM_P143_B0_Ed1
Priority:	Normal	Certificate Hash:	0C97D5BC590D6BEB74A498957C0F38 22C8FB8F16AA8B809271ABA4321012 B5FE
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric	Umbrella Organization:	Schneider Electric
Address:	35 rue Joseph Monier 92500 Rueil Malmaison France	Optional Reservation Test:	No
Product:	MiCOM P143	Serial Number:	
HW Version:	L	Publisher Legacy Variants:	
SW Version:	B0	Publisher Preferred Rates:	
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	2.3	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	09/17/2015	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Schneider-Electric China (B)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File Schneider_VAL_MiCOM_P143_B0_Ed1_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

Schneider_VAL_MiCOM_P143_B0_Ed1_Certificate.pdf	118 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------