

# IEC 61850 Certificate - IEC 61850 Certificate #2391

## Schneider MiCOM P532 [Schneider Electric]

07/08/2021 04:37 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	VAL_P532_631
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	77D8327F45AF09EAB1229191938B535 3BFDF007D1195DAE08DEA4FE7AF33 5197
<b>61850 Edition:</b>	Edition 1	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	Schneider Electric	<b>Umbrella Organization:</b>	Schneider Electric
<b>Address:</b>	Lyoner Strasse, 44-48, D-60528 Frankfurt am Main, Germany	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	Schneider MiCOM P532	<b>Serial Number:</b>	
<b>HW Version:</b>		<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	-631, -221	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	Differential, Protection	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Product Variants:</b>	
<b>Approval Date:</b>	09/17/2015		
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Schneider-Electric China (B)		
<b>Test Document:</b>			

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File Schneider\_VAL\_P532\_631\_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

### Files

Schneider\_VAL\_P532\_631\_Certificate.pdf

228 KB

07/08/2021

Herbert Falk