

IEC 61850 Certificate - IEC 61850 Certificate #2392

Schneider MiCOM P841 [Schneider Electric]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	Certificate Name:	VAL_P841_A0C
Priority:	Normal	Certificate Hash:	AB51911E1B5D9FBD46438FA0993979 EABE2697A43FB7B654AF7A19BC4E3 E5307
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric	Umbrella Organization:	Schneider Electric
Address:	Building 6B/C, F Block, No. 188, Xinjun Ring Rd. Pujiang Hi-Tech Park, Minhang District, Shanghai, China	Optional Reservation Test:	No
Product:	Schneider MiCOM P841	Serial Number:	
HW Version:	K	Publisher Legacy Variants:	
SW Version:	A0C	Publisher Preferred Rates:	
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	2.3	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	09/17/2015	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Schneider-Electric China (B)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File Schneider_VAL_P841_A0C_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

Schneider_VAL_P841_A0C_Certificate.pdf

229 KB

07/08/2021

Herbert Falk