

IEC 61850 Certificate - IEC 61850 Certificate #2393

Schneider MiCOM P849 [Schneider Electric Infrastructure Business China]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	Certificate Name:	VAL_P849_A0A
Priority:	Normal	Certificate Hash:	CA1B84EC9720215ED6C3BFBF1096C AF736187EE07E5597D607D4CBA7F2E 30F39
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric Infrastructure Business China	Umbrella Organization:	Schneider Electric
Address:	Building 6B/C, F Block No. 188, Xinjun Ring Rd. Pujiang Hi-Tech Park, Minhang District, Shanghai	Optional Reservation Test:	No
Product:	Schneider MiCOM P849	Serial Number:	
HW Version:	K	Publisher Legacy Variants:	
SW Version:	A0A	Publisher Preferred Rates:	
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	2.3	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	09/17/2015	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Schneider-Electric China (B)		
Test Document:			
Description This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File *Schneider_VAL_P849_A0A_Certificate.pdf* added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to *Schneider Electric*

Files

Schneider_VAL_P849_A0A_Certificate.pdf

201 KB

07/08/2021

Herbert Falk