

# IEC 61850 Certificate - IEC 61850 Certificate #2394

## TESLA 4000 [M/s. Easun Reyrolle Ltd. (ERLPhase)]

07/08/2021 04:37 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	UARC/PL/C0030/2012
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	CF1B219A21778A26B50477BA6CFF43 C301F15AEEA4DFD1DCE75EA4DB9E1 FE43D
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	M/s. Easun Reyrolle Ltd. (ERLPhase)	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	No. 98, Sipcot Industrial Complex Hosur - 635126 India	<b>Umbrella Organization:</b>	
<b>Product:</b>	TESLA 4000	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	1.0	<b>Serial Number:</b>	
<b>SW Version:</b>	1.3	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.2b	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis,bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/17/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Central Power Research Institute India (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File UARCPLC00302012\_Easun\_Reyrolle.pdf added

### Files

UARCPLC00302012_Easun_Reyrolle.pdf	1.37 MB	07/08/2021	Herbert Falk
------------------------------------	---------	------------	--------------