

IEC 61850 Certificate - IEC 61850 Certificate #2396

MiCOM P143 [Schneider Electric]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	Certificate Name:	UARC/PL/C0060/2012
Priority:	Normal	Certificate Hash:	B56C405611AECA17A48B3A3006948D 2966F2821C10722963EA89721F0CF22 4F2
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric	Umbrella Organization:	Schneider Electric
Address:	No. 3/86-E, Ambattur Industrial Estate, Ambattur, Chennai-58, India	Optional Reservation Test:	No
Product:	MiCOM P143	Serial Number:	
HW Version:	J	Publisher Legacy Variants:	
SW Version:	46	Publisher Preferred Rates:	
Key Words:	Relay	Publisher Preferred Variants:	
Test Procedure Version:	2.3	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	09/17/2015	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File UARCPLC00602012_Schnicer_P143.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

UARCPLC00602012_Schnicer_P143.pdf

789 KB

07/08/2021

Herbert Falk