

IEC 61850 Certificate - IEC 61850 Certificate #2397

MiCOM P546 [Schneider Electric]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: UARC/PL/C0061/2012
61850 Tested Aspects:	Server	Certificate Hash: 8AAE0C506455EA95C47E4FBAF32BF1E17234D9FF7BADCD190301ECD3A14C942FD
Company:	Schneider Electric	Vendor Artifact File Name:
Address:	No. 3/86-E, Ambattur Industrial Estate, Ambattur, Chennai-58, India	Vendor Artifact Hash:
Product:	MiCOM P546	Umbrella Organization: Schneider Electric
HW Version:	K	Optional Reservation Test: No
SW Version:	57	Serial Number:
Key Words:	Differential, Distance, Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	2.3	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	09/17/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Central Power Research Institute India (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File UARCPLC00612012-Schneider-546.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

UARCPLC00612012-Schneider-546.pdf	783 KB	07/08/2021	Herbert Falk
-----------------------------------	--------	------------	--------------