

IEC 61850 Certificate - IEC 61850 Certificate #2399

2012-BHEL TPU-01 [M/s. Bharat Heavy Electricals Ltd.]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	UARC/PL/C0074/2012
61850 Edition:	Edition 1	Certificate Hash:	8367B87D981F4D1EC62062E5DBB4CF D71DAE4DD9D9BBD58BD08619E87F8 73CCD
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	M/s. Bharat Heavy Electricals Ltd.	Vendor Artifact Hash:	
Address:	Corporate Research and Development, Vikas Nagar, Hyderabad - 500093 India	Umbrella Organization:	
Product:	2012-BHEL TPU-01	Optional Reservation Test:	No
HW Version:	1.0	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/17/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File UARCPLC00742012-BHEL-TPU01.pdf added

Files

UARCPLC00742012-BHEL-TPU01.pdf	802 KB	07/08/2021	Herbert Falk
--------------------------------	--------	------------	--------------