

IEC 61850 Certificate - IEC 61850 Certificate #2400

MiCOM P645 [Schneider Electric]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	Certificate Name:	UARC/PL/C0095/2012
Priority:	Normal	Certificate Hash:	1210096E32697C353D92D1297325DD ED8143EB6AD3C59E5F1988E4122D42 5460
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric	Umbrella Organization:	Schneider Electric
Address:	No. 3/86-E, Ambattur Industrial Estate, Ambattur, Chennai-58, India	Optional Reservation Test:	No
Product:	MiCOM P645	Serial Number:	
HW Version:	K	Publisher Legacy Variants:	
SW Version:	04	Publisher Preferred Rates:	
Key Words:	Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	2.3	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Product Variants:	
Approval Date:	09/17/2015		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4		
Current Test Lab Name:	Central Power Research Institute India (A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File UARCPLC00952012_Schnicer_P645.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

UARCPLC00952012_Schnicer_P645.pdf	1.2 MB	07/08/2021	Herbert Falk
-----------------------------------	--------	------------	--------------