

# IEC 61850 Certificate - IEC 61850 Certificate #2402

## MiCOM P345 [Schneider Electric]

07/08/2021 04:37 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	UARC/PL/C0099/2012
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	948DC8732EA31AF336C4C8C81DE6F D10CF6F2A652A5C415BA6966D1F3C4 5D714
<b>61850 Edition:</b>	Edition 1	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	Schneider Electric	<b>Umbrella Organization:</b>	Schneider Electric
<b>Address:</b>	No. 3/86-E, Ambattur Industrial Estate, Ambattur, Chennai-58, India	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	MiCOM P345	<b>Serial Number:</b>	
<b>HW Version:</b>	K	<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	36	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Product Variants:</b>	
<b>Approval Date:</b>	09/17/2015		
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Central Power Research Institute India (A)		
<b>Test Document:</b>			

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File UARCPLC00992012-Schneider-345.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

### Files

UARCPLC00992012-Schneider-345.pdf

783 KB

07/08/2021

Herbert Falk