

IEC 61850 Certificate - IEC 61850 Certificate #2404

COREL NII/JNC 268 [M/s. JVS Electronics Pvt Ltd.]

07/08/2021 04:37 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	UARC/PL/C0104/2012
61850 Edition:	Edition 1	Certificate Hash:	48BC5CA6963E340692F7AA805B3FC9 5CA75AE05A508B1D55D574C403B742 87AC
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	M/s. JVS Electronics Pvt Ltd.	Vendor Artifact Hash:	
Address:	121, Manchanayakana Halli, Bidadi Hobli, Bang-Mys Highway, Ramanagara Dst - 562109 India	Umbrella Organization:	
Product:	COREL NII/JNC 268	Optional Reservation Test:	No
HW Version:	693-3A	Serial Number:	
SW Version:	1.21	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/17/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:37 PM - Herbert Falk

- File UARCPLC01042012_JVS_Electronics.pdf added

Files

UARCPLC01042012_JVS_Electronics.pdf	1.37 MB	07/08/2021	Herbert Falk
-------------------------------------	---------	------------	--------------