

# IEC 61850 Certificate - IEC 61850 Certificate #2407

## TA612 [CG Power & Industrial Solutions Ltd.]

07/08/2021 04:37 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	UARC/SASL/C004/2014
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	CB62DBF4C659FCA72BD99CFE7468C 4D615CF2D707789DA37DC8AE14F653 DB643
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	CG Power & Industrial Solutions Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	A-3, MIDC, Ambad, Nashik - 422010, India	<b>Umbrella Organization:</b>	
<b>Product:</b>	TA612	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	HW008	<b>Serial Number:</b>	
<b>SW Version:</b>	02-01-07	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis,bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/17/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Central Power Research Institute India (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:38 PM - Herbert Falk

- File UARCSASLC0042014\_TPR\_CromptonGreaves.pdf added

### Files

UARCSASLC0042014_TPR_CromptonGreaves.pdf	802 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------