

IEC 61850 Certificate - IEC 61850 Certificate #2412

Schneider MiCOM P645 [Schneider Electric Infrastructure Business China]

07/08/2021 04:38 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: VAL_P645_04V
61850 Tested Aspects:	Server	Certificate Hash: 59B3F3BEBBEA93F6D3EE2021CAD5E EACC07BC2A3CA2681C915EF74E28E 9E9B8F
Company:	Schneider Electric Infrastructure Business China	Vendor Artifact File Name:
Address:	Building 6B/C, F Block, No. 188, Xinjun Ring Rd. Pujiang Hi-Tech Park, Minhang District , Shanghai	Vendor Artifact Hash:
Product:	Schneider MiCOM P645	Umbrella Organization: Schneider Electric
HW Version:	K	Optional Reservation Test: No
SW Version:	04V	Serial Number:
Key Words:	Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	2.3	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	09/18/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Schneider-Electric China (B)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:38 PM - Herbert Falk

- File VAL_P645_04V_Certificate_rev1.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

