

IEC 61850 Certificate - IEC 61850 Certificate #2414

NSR-303 [NARI Technology Co., Ltd.]

07/08/2021 04:38 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: ZE 14 12 80863 018
61850 Tested Aspects:	Server	Certificate Hash: 37BF69B29295AFEE27F25582CE2B40 36B8F4DB6018EB10D2F4DBBDB477A DB5B8
Company:	NARI Technology Co., Ltd.	Vendor Artifact File Name:
Address:	No. 19 Chengxin Avenue, 211106, 211106 Nanjing, Jiangsu People's Republic of China	Vendor Artifact Hash:
Product:	NSR-303	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	2.00	Serial Number:
Key Words:	Differential, Protection	Publisher Legacy Variants:
Test Procedure Version:	2.3	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	09/18/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	TUV SUD Germany (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:38 PM - Herbert Falk

- File ZE_14_12_80863_018_NARI_NSR-303_IEC61850_Server_Ed1.pdf added

Files

ZE_14_12_80863_018_NARI_NSR-303_IEC61850_Server_Ed1.pdf	801 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------