

IEC 61850 Certificate - IEC 61850 Certificate #2415

NSR-302 [NARI Technology Co., Ltd.]

07/08/2021 04:38 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: ZE 14 12 80863 019
61850 Tested Aspects:	Server	Certificate Hash: A8A9E0CA2CA07B96C7E1D822AF341 5137A28B2F8BB2E0CD8FEF45F983F6 E768D
Company:	NARI Technology Co., Ltd.	Vendor Artifact File Name:
Address:	No. 19 Chengxin Avenue, 211106, 211106 Nanjing, Jiangsu People's Republic of China	Vendor Artifact Hash:
Product:	NSR-302	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	1.00	Serial Number:
Key Words:	Distance, Protection	Publisher Legacy Variants:
Test Procedure Version:	2.3	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	09/18/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	TUV SUD Germany (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:38 PM - Herbert Falk

- File ZE_14_12_80863_019_NARI_NSR-302_IEC61850_Server_Ed1.pdf added

Files

ZE_14_12_80863_019_NARI_NSR-302_IEC61850_Server_Ed1.pdf	802 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------