

IEC 61850 Certificate - IEC 61850 Certificate #2416

NSR-371 [NARI Technology Co., Ltd.]

07/08/2021 04:38 PM - Herbert Falk

Status:	Approved	Certificate Name:	ZE 14 12 80863 020
Priority:	Normal	Certificate Hash:	C4A7BF79B5992B88BE6CEBB5FDD73 6E99377C82E0810068CC9E75E9928B 7DC8A
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	NARI Technology Co., Ltd.	Umbrella Organization:	
Address:	No. 19 Chengxin Avenue, 211106, 211106 Nanjing, Jiangsu People's Republic of China	Optional Reservation Test:	No
Product:	NSR-371	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	1.00	Publisher Preferred Rates:	
Key Words:	Protection	Publisher Preferred Variants:	
Test Procedure Version:	2.3	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	09/18/2015	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		
Test Document:			
Description This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:38 PM - Herbert Falk

- File ZE_14_12_80863_020_NARI_NS-371_IEC61850_Server_Ed1.pdf added

Files

ZE_14_12_80863_020_NARI_NS-371_IEC61850_Server_Ed1.pdf 798 KB 07/08/2021 Herbert Falk