

IEC 61850 Certificate - IEC 61850 Certificate #2419

REC670 [ABB AB]

07/08/2021 04:38 PM - Herbert Falk

Status:	Approved	Certificate Name:	74105096-OPE/INC 14-1384
Priority:	Normal	Certificate Hash:	E031C8464DD0A4ADCB639ACC3132F 5331C7D1602497E8F2C4A7837B7BC1 E8E53
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	ABB AB	Umbrella Organization:	
Address:	SA Products S-721 59 Vasteras Sweden	Optional Reservation Test:	No
Product:	REC670	Serial Number:	
HW Version:	1MRK001535-29	Publisher Legacy Variants:	
SW Version:	2.0	Publisher Preferred Rates:	
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	09/18/2015	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:38 PM - Herbert Falk

- File 14-1384_ABB_REC670_REB670_RED670_REG670_REL670_RES670_RET670_ServerEd2_Certificate.pdf added

Files

14-1384_ABB_REC670_REB670_RED670_REG670_REL670_RES670_RET670_ServerEd2_Certificate.pdf

Herbert Falk