

IEC 61850 Certificate - IEC 61850 Certificate #2420

HyCon Controller [Voith Hydro Holding GmbH & Co. KG]

07/08/2021 04:38 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: ZE 14 08 89431 001
61850 Tested Aspects:	Server	Certificate Hash: C17D3AA097ABC9115388073499F97037BAFB273FC47EE86B2F3C6913A57C92DE
Company:	Voith Hydro Holding GmbH & Co. KG	Vendor Artifact File Name:
Address:	AlexanderstraBe 11 89522 Heidenheim, Germany	Vendor Artifact Hash:
Product:	HyCon Controller	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	1.0.56	Serial Number:
Key Words:		Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Substitution (B3), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	09/18/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	TUV SUD Germany (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:38 PM - Herbert Falk

- File 14-ZE_14_08_89431_001-VOITH_HyCon_Controller_IEC61850Ed2-Ser added

Files

14-ZE_14_08_89431_001-VOITH_HyCon_Controller_IEC61850Ed2-Ser.pdf	200 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------