

IEC 61850 Certificate - IEC 61850 Certificate #2421

Siprotec 5 7KE85 [Siemens AG, EM EA PRO]

07/08/2021 04:38 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74106487-OPE/INC 15-0387
61850 Edition:	Edition 2	Certificate Hash:	D7CAB143423EA77D19980987F1D879 F4C667AC2DAB5A2A8DDEE18FE8EAF A37A3
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens AG, EM EA PRO	Vendor Artifact Hash:	
Address:	Wernerwerkdammm 5 13629 Berlin Germany	Umbrella Organization:	
Product:	Siprotec 5 7KE85	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	06.01	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/18/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:38 PM - Herbert Falk

- File 15-0387_SIEMENS_7KE85_ServerEd2_certificate.pdf added

Files

15-0387_SIEMENS_7KE85_ServerEd2_certificate.pdf	1.91 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------