

IEC 61850 Certificate - IEC 61850 Certificate #2425

SLP-K310 [Sanion Co., Ltd.]

07/08/2021 04:38 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2015TS00288
61850 Edition:	Edition 2	Certificate Hash:	E30259996BDC9C45860D94184DAA68 EB57B93025C8EA40AE165D53B3A6C BDFF6
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Sanion Co., Ltd.	Vendor Artifact Hash:	
Address:	#208, Acetechno Tower, 12 Dangsang-ro 2-Gil Yeongdeungpo-Gu, Seoul, 150-992 Republic of Korea	Umbrella Organization:	
Product:	SLP-K310	Optional Reservation Test:	No
HW Version:	1.00	Serial Number:	
SW Version:	1.00	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/18/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:38 PM - Herbert Falk

- File 2015TS00288_SANION_SLP-K310_Server1.0_KERI_Certificate.pdf added

Files

2015TS00288_SANION_SLP-K310_Server1.0_KERI_Certificate.pdf	2.66 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------