

# IEC 61850 Certificate - IEC 61850 Certificate #2427

## Schneider Sepam M87 [Schneider Electric]

07/08/2021 04:38 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	Schneider_VAL_SepamM87_version8.0 4_
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	E84B9644A5185AF321E915BFF084A80 08B98B80437AAB9180AD8B3B762936 69C
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	Schneider Electric	<b>Umbrella Organization:</b>	Schneider Electric
<b>Address:</b>	Energy Automation Activity Usine M4, 38050 Grenoble Cedex France	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	Schneider Sepam M87	<b>Serial Number:</b>	
<b>HW Version:</b>	ACE850 2.2	<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	8.04	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Logging (B7), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	09/18/2015	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Schneider-Electric China (B)		
<b>Test Document:</b>			
<b>Description</b> This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:38 PM - Herbert Falk

- File Schneider\_VAL\_SepamM87\_version8.04\_Ed2\_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

### Files

Schneider\_VAL\_SepamM87\_version8.04\_Ed2\_Certificate.pdf

107 KB

07/08/2021

Herbert Falk