

IEC 61850 Certificate - IEC 61850 Certificate #2429

SPRECON-E-C [Sprecher Automation GmbH]

07/08/2021 04:38 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	ZE 15 05 73734 001
61850 Edition:	Edition 2	Certificate Hash:	CFAA42D03A95B0554E8FAFBAF0E659 F1245F12ABF7BDC70ADDCCDC0C00 DA11D1
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Sprecher Automation GmbH	Vendor Artifact Hash:	
Address:	FranckstraBe 51 A-4018 Linz, Austria	Umbrella Organization:	
Product:	SPRECON-E-C	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	8.39	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	09/18/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:38 PM - Herbert Falk

- File ZE 15 05 73734 001 Sprecon-E-C IEC 61850 Server Ed2.pdf added

Files

ZE 15 05 73734 001 Sprecon-E-C IEC 61850 Server Ed2.pdf	1.46 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------