

# IEC 61850 Certificate - IEC 61850 Certificate #2433

## CSEZen-F\_M\_T [M/s. C&S Electric Ltd.]

07/08/2021 04:39 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	PSD/SASL/1516/C003
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	839AD62FD6CFC8434935D63F108E3E 164F4BC4A29DDB2AB2123EAE80A7A F565B
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	M/s. C&S Electric Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	C-60, Wing-A (Opposite Parag Dairy), Phase-II, Noida - 201305 Dist: Gautam Budh Nagar, Up - India	<b>Umbrella Organization:</b>	
<b>Product:</b>	CSEZen-F_M_T	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	1.2.0.00.00	<b>Serial Number:</b>	
<b>SW Version:</b>	1.0.02.19.15	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/27/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Central Power Research Institute India (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:39 PM - Herbert Falk

- File CSElectric\_PSDSASL1516C003.pdf added

### Files

CSElectric\_PSDSASL1516C003.pdf

798 KB

07/08/2021

Herbert Falk