

IEC 61850 Certificate - IEC 61850 Certificate #2435

MiCOM P443 [Shanghai Schneider Electric Power Automation Co., Ltd.]

07/08/2021 04:39 PM - Herbert Falk

Status:	Approved	Certificate Name:	2015PUCA0001
Priority:	Normal	Certificate Hash:	15DA00B1FC8C49418DA92F1BF76E43 D780ECF43B44915BD163F7C09A01E5 882B
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Shanghai Schneider Electric Power Automation Co., Ltd.	Umbrella Organization:	Schneider Electric
Address:	No. 833, Kangqiao Road, Pudong District, Shanghai, 201315, P.R. China	Optional Reservation Test:	No
Product:	MiCOM P443	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	D1.B	Publisher Preferred Rates:	
Key Words:	Distance, Protection	Publisher Preferred Variants:	
Test Procedure Version:	2.3	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	09/27/2015	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:39 PM - Herbert Falk

- File Schneider_MiCOM P443_VD1.B_Fast Multifunction Distance Protection added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

Schneider_MiCOM P443_VD1.B_Fast Multifunction Distance Protection.19MB

07/08/2021

Herbert Falk