

IEC 61850 Certificate - IEC 61850 Certificate #2440

KEPCO IED Explorer [Korea Electric Power Corporation]

07/08/2021 04:39 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 15-056101-01-1
61850 Tested Aspects:	Client	Certificate Hash: 54166AC8C779A21F4249BAF975D78B21E5A5F3F5640B774B58FF9323452729C0
Company:	Korea Electric Power Corporation	Vendor Artifact File Name:
Address:	KEPCO, #55 Jeollyeok-ro, Naju-si, Jeollanam-do Republic of Korea, 58217	Vendor Artifact Hash:
Product:	KEPCO IED Explorer	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	1.0	Serial Number:
Key Words:		Publisher Legacy Variants:
Test Procedure Version:	1.1	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	11/10/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:39 PM - Herbert Falk

- File KEPCO IED Explorer_Testing by KTL.pdf added

Files

KEPCO IED Explorer_Testing by KTL.pdf	211 KB	07/08/2021	Herbert Falk
---------------------------------------	--------	------------	--------------