

IEC 61850 Certificate - IEC 61850 Certificate #2445

ePAQ-9425 [CG Automation Solutions]

07/08/2021 04:39 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74108592-OPE/INC 15-2795
61850 Edition:	Edition 1	Certificate Hash:	0F9E7C29209201AB1587AA79EF0B29 94E2582322BDF2A1D155BFAD20B29B 3BD0
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	CG Automation Solutions	Vendor Artifact Hash:	
Address:	60 Fadem Road Springfield, NJ 07081 USA	Umbrella Organization:	
Product:	ePAQ-9425	Optional Reservation Test:	No
HW Version:	SR CPLD 0.15	Serial Number:	
SW Version:	Link 80-01000-001P	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	11/22/2015	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:39 PM - Herbert Falk

- File 15-2795_DNVGL_CG-Automation_ePAQ9425_ePAQ9410_ePAQ9420_Serve added

Files

15-2795_DNVGL_CG-Automation_ePAQ9425_ePAQ9410_ePAQ9420_Serve.pdf 07/08/2021

Herbert Falk