IEC 61850 Certificate - IEC 61850 Certificate #2447

BE2704 [EKRA Research and Production Enterprise, Ltd.]

07/08/2021 04:39 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	74108408-OPE/INC 15-1898
61850 Tested Aspects:	Server	**Certificate Hash:**	2ECFAC3F8A89A5999B16B2BC82B0F14FC2AFD191AAAAB0C5A11A767F59A2CE46
Company:	EKRA Research and Production Enterprise, Ltd.	**Vendor Artifact File Name:**	
Address:	Yakovlev prospect, 3 428003 Cheboksary Russia	**Vendor Artifact Hash:**	
Product:	BE2704	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	562	**Serial Number:**	
Key Words:	Differential, Protection	**Publisher Legacy Variants:**	
Test Procedure Version:	2.3	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	11/22/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:39 PM - Herbert Falk

- File 15-1898_DNVGL_EKRA_BE2704_ServerEd1_Certificate.pdf added

Files

15-1898_DNVGL_EKRA_BE2704_ServerEd1_Certificate.pdf	1.71 MB	07/08/2021	Herbert Falk