

IEC 61850 Certificate - IEC 61850 Certificate #2449

Siprotec 5 [Siemens AG, EM EA PRO]

07/08/2021 04:39 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10012436-OPE/INC 15-2791
61850 Tested Aspects:	Server	Certificate Hash: CA0A47440476ADAB6F7ABB1DDD0E26C36B075DA95F58A0D18792F72DAFF2B318
Company:	Siemens AG, EM EA PRO	Vendor Artifact File Name:
Address:	Wernerwerkdamm 5 13629 Berlin Germany	Vendor Artifact Hash:
Product:	Siprotec 5	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	07.00	Serial Number:
Key Words:	Protection	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	12/05/2015	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:39 PM - Herbert Falk

- File 15-2791_DNVGL_SIEMENS_7SS85_ServerEd2_Certificate.pdf added

Files

15-2791_DNVGL_SIEMENS_7SS85_ServerEd2_Certificate.pdf	3.05 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------