

# IEC 61850 Certificate - IEC 61850 Certificate #2453

## TOR 300 AUV [Research Centre Bresler, LLC]

07/08/2021 04:40 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10012256-OPE/INC 15-2732
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	F69F7EC196456A920270074E7B6D2C 93AB5FCCC54120BD15F568FA742775 131D
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Research Centre Bresler, LLC	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	1, prospect I. Yakovleva 428000 Cheboksary Russian Federation	<b>Umbrella Organization:</b>	
<b>Product:</b>	TOR 300 AUV	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	2.15_T	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	12/05/2015	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:40 PM - Herbert Falk

- File 15-2732\_DNVGL\_IC-Bresler\_TOR300\_AUV\_KSZ\_ServerEd1\_Certificat added

### Files

15-2732_DNVGL_IC-Bresler_TOR300_AUV_KSZ_ServerEd1_Certificat.pdf	186 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------