

IEC 61850 Certificate - IEC 61850 Certificate #2454

REF611 [ABB Oy]

07/08/2021 04:40 PM - Herbert Falk

Status:	Approved	Certificate Name:	10010221-OPE/INC 15-2723
Priority:	Normal	Certificate Hash:	74E0BC1B0483AFDAECC4EB2E6B2F8 09A3E67962C24EB3804CA11443969E2 91BC
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	ABB Oy	Umbrella Organization:	
Address:	Medium Voltage Products Muottitie 2 FI-65101 Vaasa Finland	Optional Reservation Test:	No
Product:	REF611	Serial Number:	
HW Version:	G	Publisher Legacy Variants:	
SW Version:	2.0	Publisher Preferred Rates:	
Key Words:	Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	12/05/2015	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:40 PM - Herbert Falk

- File 15-2723_DNVGL_ABB_REF611_REB611_REM611_REU611_ServerEd2_cert added

Files

15-2723_DNVGL_ABB_REF611_REB611_REM611_REU611_ServerEd2_cert.pdf 07/08/2021

Herbert Falk