IEC 61850 Certificate - IEC 61850 Certificate #2456

Breslere-0107.511 [NPP Bresler, LLC]

07/08/2021 04:40 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	10012256-OPE/INC 15-2720
61850 Tested Aspects:	Server	**Certificate Hash:**	70D80DE5C8950696E5BE25D78D8948DDAB197E6098CD92E5B7CC6AC37F32B4E7
Company:	NPP Bresler, LLC	**Vendor Artifact File Name:**	
Address:	Afanasiev street 13 428000 Cheboksary Russian Federation	**Vendor Artifact Hash:**	
Product:	Breslere-0107.511	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	3	**Serial Number:**	
Key Words:	Protection	**Publisher Legacy Variants:**	
Test Procedure Version:	2.3	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	12/05/2015	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:40 PM - Herbert Falk

- File 15-2720_DNVGL_NPP-Bresler_0107.511_ServerEd1_Certificate.pdf added

Files

15-2720_DNVGL_NPP-Bresler_0107.511_ServerEd1_Certificate.pdf	2.9 MB	07/08/2021	Herbert Falk