

# IEC 61850 Certificate - IEC 61850 Certificate #2460

## 140 NOP 850 00 [Schneider Automation SAS]

07/08/2021 04:40 PM - Herbert Falk

|                                     |   |                                       |  |
|-------------------------------------|---|---------------------------------------|--|
| <b>Status:</b>                      | Approved  | <b>Test Document:</b>                 |  |
| <b>Priority:</b>                    | Normal  | <b>Certificate Name:</b>              | ZE 15 12 59947 001   |
| <b>61850 Edition:</b>               | Edition 2   | <b>Certificate Hash:</b>              | 0A96FB8D4CDC7C386C80330194DD8<br>DFD6E39EF625BC22F307CED44FD35<br>8A3221 |
| <b>61850 Tested Aspects:</b>        | Client  | <b>Vendor Artifact File Name:</b>     |  |
| <b>Company:</b>                     | Schneider Automation SAS  | <b>Vendor Artifact Hash:</b>          |  |
| <b>Address:</b>                     | 1ere Avenue - 8eme Rue, Site Horizon<br>ZI de Carros<br>06516 Carros CEDEX<br>France  | <b>Umbrella Organization:</b>         | Schneider Electric   |
| <b>Product:</b>                     | 140 NOP 850 00  | <b>Optional Reservation Test:</b>     | No   |
| <b>HW Version:</b>                  |   | <b>Serial Number:</b>                 |  |
| <b>SW Version:</b>                  | 1.0   | <b>Publisher Legacy Variants:</b>     |  |
| <b>Key Words:</b>                   |   | <b>Publisher Preferred Rates:</b>     |  |
| <b>Test Procedure Version:</b>      | 1.0   | <b>Publisher Preferred Variants:</b>  |  |
| <b>IEC 61850 Blocks Certified:</b>  | Basic Exchange (B1), Buffered Reporting (B6), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Unbuffered Reporting (B5) | <b>Subscriber Legacy Variants:</b>    |  |
| <b>Certificate/Result Reviewer:</b> | kathy.ellis   | <b>Subscriber Preferred Variants:</b> |  |
| <b>Approval Date:</b>               | 12/13/2015  | <b>Subscriber Preferred Rates:</b>    |  |
| <b>Standards Tested:</b>            | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1  |                                       |  |
| <b>Current Test Lab Name:</b>       | TUV SUD Germany (A)   |                                       |  |

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:40 PM - Herbert Falk

- File 15-ZE 15 12 59947 001-SchneiderElectrics\_NOP 850\_IEC61850Ed2 added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

### Files

15-ZE 15 12 59947 001-SchneiderElectrics\_NOP 850\_IEC61850Ed2.pdf 4 MB

07/08/2021

Herbert Falk