

IEC 61850 Certificate - IEC 61850 Certificate #2464

Q24DHCCPU-V "C-RTU" [Mitsubishi Electric Europe B.V.]

07/08/2021 04:40 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 74107647-OPE/INC 15-3052
61850 Tested Aspects:	Server	Certificate Hash: 349EF5452F566BA284EA2082235A268 AA3461E72C8E08D9CD9E47F99A62B7 D6B
Company:	Mitsubishi Electric Europe B.V.	Vendor Artifact File Name:
Address:	Mitsubishi-Electric-Platz 1 40882 Ratingen Germany	Vendor Artifact Hash:
Product:	Q24DHCCPU-V "C-RTU"	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	20589	Serial Number:
Key Words:		Publisher Legacy Variants:
Test Procedure Version:	2.3	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	01/01/2016	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:40 PM - Herbert Falk

- File 15-3052_DNVGL_Mitsubishi_Q24DHCCPU_V_ServerEd1_Certificate.p added

Files

15-3052_DNVGL_Mitsubishi_Q24DHCCPU_V_ServerEd1_Certificate.p	2.65 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------